



**Morrison Bros. Co.**  
325 E. 24<sup>th</sup> St.  
P.O. Box 238  
Dubuque, IA 52004-0238

Tel: 800-553-2709 ext. 221  
Tel: 563-583-0632 ext. 221  
Fax: 563-583-5028  
*E-mail: [rzillig@morbro.com](mailto:rzillig@morbro.com)*  
*Website: <http://www.morbro.com>*

---

February 23, 2007

Attention: Morrison Distributor

Subject: Fig. 918 Clock Gauge Alarm Battery Life Expectancy

Morrison Bros. Co. manufactures and sells a Clock Gauge/Alarm listed as Fig. 918, which is designed to indicate liquid level up to 12 feet and also provide an audible high level alarm for an aboveground fuel storage system.

Under certain conditions the batteries that supply power to the audible alarm may loose charge more rapidly than what is normally expected. This potential charge-depleting condition occurs if and when a high liquid level is reached in the tank and maintained for an extended period of time. Even though the audible alarm is switched off, the batteries will continue to be drained of power if the liquid level remains above the high level point. If this practice is standard routine, it will lead to much shorter battery life and/or increased chance of overfill if the proper test procedures are not strictly followed before every transaction.

The steps for proper and safe operation identified on the Warning Tag provided with the Fig. 918 mechanism indicate that the operator **MUST** test the alarm by pushing the alarm TEST/CANCEL button, prior to filling the tank. This insures that the batteries have power and the alarm will sound. If the alarm does not sound during this test procedure, the operator **MUST** replace the batteries and perform the test until the alarm does sound.

In most standard routines, the operator does not intentionally fill and maintain the liquid level in the tank above the high level point and therefore may never experience any unusual rapid loss of battery power.

It is the duty of Morrison Bros. Co. to warn all Morrison distributors of this condition and require that it be forwarded to those who design, install, own, and/or operate aboveground fuel storage systems that incorporate this Clock Gauge/Alarm.

**Failure to follow the installation instructions and steps for proper and safe operation could result in a malfunction of the system which may lead to an accidental product spill, property damage, fire, personal injury and/or death.**

Specific questions regarding this notification or the Fig. 918 should be directed to Morrison Bros. Co. (800) 553-4840.