

Morrison Bros. Co.

www.morbros.com

# Fig. 560, 561, 562 & 563 Series Extractors

The Morrison Extractors thread into a 4" opening on an underground storage tank. A 4" riser pipe threads into the top of the extractor for use in Stage I Vapor Recovery or to access a 317 Ball Float. Vent lines are attached to the threaded side openings or can be used to manifold multiple tanks. The threaded brass cage can be removed to allow for removal of float vent valve for repair, replacement or tank testing.

Various sizes are available. The Extractors are available with cage or without.

Fig. 560, 561, 562 and 563 have been tested and approved by the California Air Resource Board (CARB). They are not EVR Approved.

Also available is the Fig. 561P Test Plug. The Test Plug will seal a system when conducting a tank tightness test on a tank equipped with the extractor/vent valve overfill. The Test Plug threads into the extractor fitting in place of the float vent valve and remains for duration of the test. One size fits all Morrison Extractors.



Fig. 560

Fig. 561

Fig. 562

Fig. 563

I.D. NUMBER	A	B	C	D	E	HEIGHT	WIDTH	WEIGHT
560--0100 AE	4" X 4" X 2" X 2"	CI	BR	Buna	Y	7.938	7.594	18.25
560--0101 MBE	4" X 4" X 2" X 2"	CI	NA	Buna	N	7.938	7.594	15.25
561--0100 AE	4" X 4" X 2"	CI	BR	Buna	Y	7.938	6.531	15
561--0101 MBE	4" X 4" X 2"	CI	NA	Buna	N	7.938	6.531	12
562--0100 AE	4" X 4" X 3" X 2"	CI	BR	Buna	Y	7.594	7.938	17.5
562--0100 MBE	4" X 4" X 3" X 2"	CI	NA	Buna	N	7.594	7.938	14.5
563--0101 AE	4" X 4" X 3"	CI	BR	Buna	Y	7.938	6.656	15.5
563--0101 MBE	4" X 4" X 3"	CI	NA	Buna	N	7.938	6.656	12.5

**CHART KEY:**

- A**—Size
- B**—Body Material: CI (Cast Iron Epoxy Coated)
- C**—Cage Material: BR (Brass) or NA
- D**—O-Ring Material: Buna
- E**—Cage: Y (Yes) or N (No)
- Height**
- Width**
- Weight**—Shipping Weight

**Morrison Bros. Co.**  
Established 1855

P.O. Box 238 • Dubuque, Iowa 52004-0238  
563.583.5701 (tel) • 800.553.4840 • 563.583.5028 (fax)  
www.morbros.com