

Morrison Bros. Co.

AST Products With Florida Approval



1018 Electronic AST Gauge & Overfill Alarm

Approval Date: December 22, 1999

Approval Number: EQ411

This tank monitoring system provides a convenient and economical solution to inventory management needs, while also providing reliable overfill prevention.



516 5 Gallon AST Spill Container Series

Approval Date: December 29, 2008

Approval Number: EQ725

Installed on aboveground storage tanks for the purpose of containing spills and drips from the fill nozzle.



9095S 2" AST Overfill Prevention Valve

Approval Date: December 21, 2007

Approval Number: EQ696

The Overfill Prevention Valve is designed for use on low profile aboveground storage tanks that require a high level shut-off. The valve terminates the fill when the product reaches the preset level. The valve can be retrofitted on existing tanks and fits into a 2" opening.




FMM Overfill Warning Valve for Used Oil Systems Series

Approval Date: February 9, 2004

Approval Number: EQ576

The Overfill Warning Valve (OWV) is used to shut off the air supply to the pump when the tank approaches full capacity. Air is diverted to the optional audible signal when liquid level reaches 90%.



918TCP AST Overfill Alarm

Approval Date: August 5, 2002

Approval Number: EQ536

The 918TCP provides an audible alarm for a high level warning. The system incorporates an alarm box and a single-point level sensor. Works on tanks up to 35' high.



515 AST Remote Spill Container

Approval Date: July 3, 2002

Approval Number: EQ535

The spill container, for use on aboveground storage tanks, is used for the purpose of containing fuel spillage during remote tank filling operations.



918/918F Clock Gauge Alarm

Approval Date: April 24, 2002

Approval Number: EQ527

The clock gauge is used for measuring liquid level in aboveground storage tanks. It uses a built-in high level warning alarm to alert users.



922 Combination Vent/Overfill Alarm

Approval Date: February 10, 2002

Approval Number: EQ227

The 922 alerts you when your aboveground storage tank is near full, while also allowing the tank to breathe

during filling and dispensing operations.



9095A Overfill Prevention Valve Series

Approval Date: December 17, 1998

Approval Number: EQ356

Used in a tight fill application, the valve will automatically shut-off product flow when the liquid level reaches a preset warning level, thus eliminating overflow. After shut-off the product is then allowed to drain from the highest point allowing the nozzle to be removed without spilling.



517 3.5 and 518 7.5 Gallon AST Spill Container Series

Approval Date: November 2, 1998

Approval Number: EQ345

Installed on aboveground storage tanks for the purpose of containing spills and drips from the fill nozzle.